THERMAL
THERMAL PRODUCTS PTY. LTD.
www.thermalproducts.com.au
178 - 180 HOLT PARADE
THOMASTOWN VIC 3074
PH - (03) 9464 0822
FX - (03) 9464 0630
Sales@thermalproducts.com.au

**VKL2201**




**VKL2301**




| CONTROL THERMOSTAT | |
|---|---|
| **Contacts:** | Single Pole |
| **Function:** | Break on Temp Rise<br>Make on Temp Fall |
| **Voltage:** | 240v AC |
| **Load Current:** | 16 Amps Resistive |
| **Switch Acton:** | 1C on Opening<br>2C on Closing |

| OVERTEMP THERMOSTAT | |
|---|---|
| **Contacts:** | Single Pole |
| **Function:** | Break on Temp Rise |
| **Voltage:** | 240v AC |
| **Load Current:** | 16 Amps Resistive |
| **Switch Acton:** | 3BH on Opening |




***WARNING:***

**1. ALL WIRING OF THE THERMOSTAT SHALL CONFORM TO AS3100 & IS TO BE INSTALLED BY A LICENSED ELECTRICTION.**

**2. ELECTRICALLY ISOLATE THERMOSTAT FROM MAINS SUPPLY BEFORE DISCONNECTING. FAILURE TO DO SO CAN RESULT IN AN ELECTRIC SHOCK**